



FDNY

www.nyc.gov/fdny

Kam Chan P. E.

Lead Engineer / Administrative Engineer of Technology Management
Bureau of Fire Prevention

CERTIFICATE OF APPROVAL # 4995

**THIS CERTIFICATE IS REVOCABLE, NOT TRANSFERABLE
AND EXPIRES ON April 17, 2020**

May 24, 2017

Terry A. Tabler
VP, Risk Management
Legend Brands / ProRestore Products
15180 Josh Wilson Rd
Burlington, WA 98233

F.P. Index#: 0706010L

FPIMS#: 30116727

By order of Fire Commissioner, Daniel A. Nigro, and pursuant to Section FC112 of the New York City Fire Code, the following materials may be acceptable for renewal for use provided the conditions outlined below are in full compliance.

Manufacturer:	Legend Brands / ProRestore Products (previously AKA II REP-Z, Inc.)
Product:	Flame-resistant Compound
Trade Name:	Unsmoke®Unflame
Pertinent Code	New York City Fire Code Chapter 8 (including Section FC 801.8) and Fire Department rule 3 RCNY Section 805-01
Prescribed Tests:	NFPA Standard 701-1999 - Test Method 1
Testing Laboratory:	Commercial Testing Company Test Report #: 01-03321 Issued on March 26, 2001
Description:	Product is a water-based liquid flame retardant.

Fire Department, City of New York

9 MetroTech Center, Brooklyn New York 11201-3857

May 24, 2017

EXPIRES ON April 17, 2020

Conditions of Approval:

1. The formulation/chemical composition of the above referenced flame-resistant materials shall be as indicated in the original application and shall not be changed in any way without prior written approval of the Fire Department.
2. The use of flame-resistant fabrics shall be certified only by a person holding a Fire Department Certificate of Fitness. Please call (718) 999-1988 to obtain detailed information on how to obtain Certificate of Fitness.
3. The use of flame-resistant chemicals shall comply with all applicable New York City codes, rules and regulations including New York City Fire Code Chapter 8 and Fire Department rule 3 RCNY Section 805-01.
4. The effectiveness of flame-resistant materials is significantly reduced when the flame-resistant materials are dry cleaned or washed. The Fire Department requires the flame-retardant treated materials that have been dry cleaned or washed to be re-treated with flame-retardant or removed from the premises. After the materials have been re-treated with flame-retardant, the Certificate of Fitness holder must file a new affidavit with the Fire Commissioner.
5. When the flame-resistant materials have been accepted, they may be used on the premises for a period of up to three years or until the materials are washed, dry cleaned or otherwise rendered ineffective. This three years period is officially called the period of acceptance. After the period of acceptance has expired, the owner of the building may apply to renew acceptance. Acceptance will only be renewed after the materials have passed a new field flame test. Acceptance may be renewed for up to three years, after which time materials must be either re-treated with flame-retardant or removed from the premises.
6. Certificate of Approval number shall be plainly and permanently stamped or otherwise fixed upon each product by the applicant. The dry cleaning and washing of the above referenced flame-resistant materials must be recorded by the owner of the building and made available to Fire Department inspectors upon request.
7. The New York City Fire Department Certificate of Approval does not grant the right to use any trademark associated with the New York City Fire Department (the letters FDNY, the FDNY Shield design, the FDNY Maltese Cross design and the seal of the City of New York). The unauthorized use of trademarks in connection with the sale of commercial goods or services violates federal and state laws.
8. The Fire Department's conditions of approval shall be enumerated in the user manuals and sales brochures that will be provided to New York City buyers and users.
9. The Fire Department Certificate of Approval does not constitute an endorsement or recommendation of your product by the Fire Department, but is a certification that your product as represented meets the standards as of the date of issuance.

Certificate of Approval #4995 for Legend Brands / ProRestore Products
Flame-resistant Compound – Unsmoke®Unflame

May 24, 2017

EXPIRES ON April 17, 2020

10. The Fire Department reserves the right to withdraw this approval at any time in the event there is a reasonable doubt that the product does not operate or perform as required by code, the conditions of this approval or as represented in your application.

Any person who fails to comply with the conditions as outlined in this approval will be subject to enforcement action which may include fines and imprisonment.

Any change in company name or ownership, product name, chemical composition or model number of any product included on this certificate must be immediately reported to this Department in writing.

Very truly yours,



Kam Chan, P.E.

COA4995Renewal (5-24-17)

cc: Ann Kowalecki (Legend Brands)